

**Logan East Rural Water System
Managers Report**

Activities during November 2023
Reported at December 2023 meeting

Gallons pumped	9,342,000	Scribner booster pumped	643,500
Gallons sold	8,202,800	Fontanelle booster pumped	1,990,400
	12 % loss		

- Nov 9 Shawn-Locates & checked PRV JJ –Fixed meters
- Nov 13 Shawn – Samples & locates JJ – fixed meters
- Nov 14 Shawn – Samples & locates JJ – Fixed metersm, locates
- Nov 15 Shawn – Sample Wesley well JJ – locates
- Nov 16 Both – repair leak Cr 39 & P Burt County
- Nov 17 Both – Finished conduit at Font tower
- Nov 20 Shawn – Locates & with Ron to Johnson well area JJ – read meters
- Nov 21 Shawn – Locates JJ – read meters
- Nov 22 Shawn – Locates & checked PRV JJ – checked sites
- Nov 27 JJ – service calls:
740 CR 13/Derek Brockermier, 3924
CR F/Vaughn Trask, 2020 CR
2/Cynthia Svendsen, & then locates.
- Nov 28 JJ – Locates
- Nov 29 JJ – Service call 3080 CR AB repair
u-bar/John Koehler, and locates
- Nov 30 JJ – Checked sites & locates
- Dec 1 JJ – Checked sites, locates, repair
leak CR 44 & F-Tekamah bottom
- Dec 4 Shawn – locates JJ – checked pressure 1790 CR
J/Billy Johnson, and fixed meters
- Dec 5 Meeting with Midwest Assistance Program for lead service rules.

MINUTES OF REGULAR
LOGAN EAST RURAL WATER SYSTEM
ADVISORY COMMITTEE MEETING
7:30 p.m. December 11, 2023 Monday
LOGAN EAST RURAL WATER SYSTEM OFFICE – OAKLAND, NE

The regular meeting of the Logan East Rural Water System Advisory Committee was called to order by Ron Dierking-Chairman of the Advisory Committee on Monday December 11, 2023 at 7:00 p.m. in the Logan East Rural Water System Office Oakland, Nebraska. The Publication of Meeting Notice was printed in the Oakland Independent newspaper on December 7, 2023.

The Nebraska Open Meeting Act information is posted by the entrance door.

Roll call was taken with 7 of the 9 committee members present. Present: Dierking, Dam, Fehrer, Hagerbaumer, Johnson, Kruger, and Lydick, Absent: Scheer & Wulf. Roll call of Lower Elkhorn NRD appointed members. Present: Gary Loftis Absent: Roger Gustafson. Also present: Brian Bruckner, LENRD manager.

Fehrer made the motion & was seconded by Hagerbaumer to adopt the agenda. Aye: All. Nay: none. Absent: Scheer & Wulf. **MOTION CARRIED.**

Minutes of the November 13, 2023 meeting were read. Fehrer made the motion and was seconded by Hagerbaumer to approve the minutes. Aye: All. Nay: none. Absent: Scheer & Wulf. **MOTION CARRIED**

Income & expense reports were given. 21 customers still owe for October water. All customers receiving disconnect letters have responded

The current LERWS hook up fee for a new water service is \$3,500. Discussion was held on costs and the committee feels it's time to increase the fee that has been in effect since 2011.

Dam made a motion and was seconded by Lydick to recommend to the LENRD an increase in the Logan East Rural Water System hook up fee making it \$4,000. Starting January 1, 2024. Aye: Dierking, Dam, Fehrer, Hagerbaumer, Johnson, Kruger, Lydick, Absent: Scheer and Wulf. **MOTION CARRIED**

The 8" water main along County Road C in Dodge county-east of the Scribner booster pump was again discussed. Blahak adjusted the pressures on 12-11-2023. He will watch the gauges in the next few weeks and re-adjust as needed. Blahak & Johansen have also noticed water at the base of the Scribner tower. They will continue to watch to determine if there is a leak in the line to the tower or if it's a landscaping problem. Employees also reported new additional rock needs to be added at other LERWS sites.

New well search: The irrigation wells tested on the Johnson & Wesley farms have results that are within some of the qualifying limits. Landowners will be contacted to see if possible test wells could be drilled. Discussion was held on renting the one acre plot on the Roy Miller test well site. No action was taken, it will be tabled until the January 2024 meeting.

Blahak gave the managers' report (see attached copy).

The next meeting will be January 8, 2024 at the LERWS office in Oakland at 7:00 p.m.

Being no further business Dierking adjourned the meeting at 8:20 p.m.

We, the Logan East Rural Water System Advisory Committee, recommend that the Lower Elkhorn NRD accept these minutes.

I, the undersigned acting secretary of the Logan East Rural Water System Advisory Committee, hereby certify that the foregoing is a true and correct copy of the proceedings by the Advisory Committee on December 11, 2023.

Laurie Schold
Logan East Rural Water System

Others present: Shawn Blahak, JJ Johansen, LERWS employees
Brian Bruckner, LENRD Manager

_____ Logan East Rural Water System
Ron Dierking, Chairman

